

## ✓ Frequent Walk-Through Inspection Checklist

<b>Date Of Inspection</b>						
<b>Release Detection System:</b> Inspect for proper operation.						
<b>Spill Buckets:</b> Ensure spill buckets are clean and empty.						
<b>Overfill Alarm:</b> Inspect for proper operation. Can a delivery person hear or see the alarm when it alarms?						
<b>Impressed Current System:</b> Inspect for proper operation.						
<b>Fill And Monitoring Ports:</b> Inspect all fill/monitoring ports and other access points to make sure that the covers and caps are tightly sealed and locked.						
<b>Spill And Overfill Response Supplies:</b> Inventory and inspect the emergency spill response supplies. If the supplies are low, restock the supplies. Inspect supplies for deterioration and improper functioning.						
<b>Dispenser Hoses, Nozzles, And Breakaways:</b> Inspect for loose fittings, deterioration, obvious signs of leakage, and improper functioning.						
<b>Dispenser And Dispenser Sumps:</b> Open each dispenser and inspect all visible piping, fittings, and couplings for any signs of leakage. If any water or product is present, remove it and dispose of it properly. Remove any debris from the sump.						
<b>Piping Sumps:</b> Inspect all visible piping, fittings, and couplings for any signs of leakage. If any water or product is present, remove it and dispose of it properly. Remove any debris from the sump.						

Your initials in each box below the date of the inspection indicate the device/system was inspected and OK on that date.